LogITm8
SCAN • CAPTURE • LOG

Pressure Log Report

L8-PT-1042-01

Job #: L8-1042

JOB DETAILS

JOB NAME
Workshop pipework - Spool set A

CLIENT
Example Engineering

SITE NAME
Demo Workshop - Bay 2

TEST PARAMETERS

DATE
28/09/2026

TECHNICIAN
Jordan Lee

TEST ASSEMBLY ID
SP-001 to SP-004

REQUIRED TEST PRESSURE
1500 kPa

TEST MEDIUM
Water

REQUIRED TEST DURATION
15 minutes

TEST RESULTS

TEST START
28/09/2026, 09:00:00 am

START PRESSURE
1580 kPa

TEST END
28/09/2026, 09:15:20 am

FINISH PRESSURE
1509 kPa

TEST DURATION
15m 20s

TEST PRESSURE LOSS CALCULATION
71.00 kPa (4.5%)

ADDITIONAL DETAILS

REPORT TYPE
Demonstration sample - fictional job details

PHOTOS



Photo 1 - Gauge Calibration Data

28/09/2026, 08:33:18 am



Photo 2 - Pipeline Test Assembly

28/09/2026, 08:33:48 am



Photo 3 - Test Start Gauge

28/09/2026, 09:00:00 am



Photo 4 - Test Finish Gauge

28/09/2026, 09:15:20 am

COMMENTS

Sample comment: pipework test completed and readings recorded for manager review.

PASS